



Non-Hospital Medical and Surgical
Facilities Accreditation Program

ACCREDITATION STANDARDS

Heating, Ventilation and
Air Conditioning (HVAC)

Copyright © 2023 by the Non-Hospital Medical and Surgical Facilities Accreditation Program and the College of Physicians and Surgeons of British Columbia.

All rights reserved. No part of this publication may be used, reproduced or transmitted, in any form or by any means electronic, mechanical, photocopying, recording or otherwise, or stored in any retrieval system or any nature, without the prior written permission of the copyright holder, application for which shall be made to:

Non-Hospital Medical and Surgical Facilities Accreditation Program
College of Physicians and Surgeons of British Columbia
300-669 Howe Street
Vancouver BC V6C 0B4

The Non-Hospital Medical and Surgical Facilities Accreditation Program and the College of Physicians and Surgeons of BC has used their best efforts in preparing this publication. As websites are constantly changing, some of the website addresses in this publication may have moved or no longer exist.

No.	Description
HVAC1.0	HEATING, VENTILATION AND AIR CONDITIONING
HVAC1.1	

No.	Description
HVAC1.2.4	M The HVAC system provides appropriate relative humidity control in the procedure room(s). The HVAC system provides appropriate relative humidity control in the procedure room(s).
HVAC1.2.5	M There is local readout of relative pressurization in each procedure room. There is local readout of relative pressurization in each procedure room.
HVAC1.2.6	M The HVAC system provides appropriate relative pressurization control in the procedure room(s). The HVAC system provides appropriate relative pressurization control in the procedure room(s).

No.	Description
HVAC1.4.2	M The HVAC systems provides appropriate temperature control in the MDR clean room. The HVAC system provides appropriate temperature control in the MDR clean room.
HVAC1.4.3	M There is local readout of relative humidity in the MDR clean room. There is local readout of relative humidity in the MDR clean room.

No.	Description
HVAC1.6.5	M Secondary filters have a minimum MERV rating of 14. - j l

No.	Description
HVAC1.6.10	M Fan coils, drain pans and induction and finned units are inspected and cleaned semi-annually. <i>(The following text is a distorted representation of the original content and is not legible.)</i>

